

Keeley Construction Top 10 Good Catches for the Week of 11/06/23

Rank	Submitted By	Group	GC Type	ObservationMade	Deficiencies	Recommendation Eliminate Occurance
1	Ryan Murphy	Building	Fall Protection / Ladders / Scaffolds	Standing on the top step of a ladder	Potential for a fall	Use the right tool for the job. Never step up on the top step
2	Luke Murphy	Building	Strains and Sprains	No Stretch and flex	Did not stretch before work	Always start the day out with stretching
3	John Nolan	Civil	Rigging	Inspection of rigging	3 hooks on 4 way missing or broken latches	Inspect your rigging
4	Bronson Holland	Building	Strains and Sprains	Access for workers and hauling trash to dumpster was not very good to use due to uneven surface.	Muscle strains from trying to haul material out and have to struggle	Access should be talked about during pre activity meeting to make sure access is in good condition and easily traveled.
5	Brian Pate	Building	Fall Protection / Ladders / Scaffolds	brick masons hydromobile scaffold material slide gate was not closed all of the way	Fall hazard	ensure material slide gate and rail is functioning properly and clear of debris prior to elevating from the ground
6	JR Winningham	Civil	Vehicular/Equipment	Operator noticed while doing pre inspection on rental skid loader there was no hydraulic fluid in machine	Extremely low on hydraulic fluid	Continue doing pre inspection even if it's a rental
7	Michael Cunningham	Paving	Other	After spraying paver lines laid the spray can down in the island. Wind picked up the can and put it in the path of the roller.	Need to stow all loose items	Good housekeeping
8	Jeffrey Jones	Civil	Excavations	Barricades need to be installed along excavation	Need delineators and flagging	Make sure to have that at the start of the job or excavation at hand
9	Ken Hicks	Building	Electric/Tools	Powder actuate shot.	Shot just thrown on the floor.	Send people back through orientation.
10	Brian Pate	Building	PPE	brick mason was witnessed cutting a cmu block with a demo saw and no face field	Improper PPE	ensure all proper ppe is readily available at place of work