

**Keeley Construction Top 10 Good Catches for the Week of 12/04/23**

Rank	Submitted By	Type of Good Catch Group	Observation Made	Deficiencies	Corrections Made	Recommendation to Eliminate Recurrences
1	Brandon Recar	Caught Between/Struck By	Clamp on concrete pump hose was slowly opening up	There are very high pressured hoses and if they bust workers at a close and not so close could get injured sprayed with concrete hit with the hose	Stopped pump backed off the pressure before removing clamp re adjusting it and putting another safety pin in the clamp	Remind everyone in jsa to stay away from hoses when pumping and always pay attention and be aware of what's going on around you not talking on the phone or stuff like that
2	Brian Pate	Fall Protection	trade partner was observed getting ready to cut metal roof decking(penetration for roof hatch) without face shield or appropriate fall protection(fall hazard would occur after decking was cut)	insufficient ppe/fall protection	trade partners instructed to stop, conversation was had making him aware of the hazards that he was about to be exposed to/JSA was re-visited and was properly discussed and documented/appropriate ppe and fall protection was gathered and worn prior to work taking place	ensure jsa is followed, correct conversations and documentation took place prior to work, just not followed
3	David Kline	Fall Protection	grating was set preventing the crew from using EZ line tie off system	crew could not find any proper tie off points to do bolt up	crew will take down one EZ line and install it below the grating so they can reach all points that need bolted up	Crew was looking ahead and saw this issue before it became a problem. no corrective action will be needed
			Bunge safety noticed ironworkers were using an extension ladder to access 2nd floor	Bunge safety rules prohibits the use of extension ladders	ironworkers removed the ladder from the job site	waiting on a permit from Bunge safety before the ladder may be used
4	Don Recar	Excavations	Fence needed to be added to keep people away from excavation	Potential fall hazard	Corrected immediately	Discuss in JSA
5	Isaac Corson	Caught Between/Struck By	Noticed someone about to grease skid with arms in the air without releasing the safety arm on the lift cylinder.	Hydraulics could fail and drop arms causing serious injury	Explained to employee the potential hazard of not installing that safety bar.	Explain the safety measures of equipment to crew members during next JSA
6	Jason Goguen	Vehicular/Equipment	installing fume hood blowers on concrete pads, moving equipment with fork lift.	operator using forklift not using a spotter in close proximity of plant buildings.	corrected the operator when 10 ft from plant equipment and buildings to have a spotter.	Added the spotter to JSA
7	Jason Myatt	Fall Protection	Our sub had their anchor point for their tie off location back above a structure and then was walking out onto a platform that was outside that structure. If they would have fallen the tie off location would have caused them to swing back into the wall below causing what has potential for serious injury.	Did not want to hang the fall arrest system for the main structure overhead due to the height of the structure.	They where going to finish the day working out of the lift and then hang the retractable overhead once they get some rope to be able to pull the line down to tie off tomorrow.	Just have to make sure everyone is educated on how fall arrest systems are designed to work
	Joe Sterkis		I noticed a employee using a Baker scaffold without locking the wheels	not securing the scaffold in place before using it	i stopped him and explained the importance of it	make sure all trades are aware of the rules
8	JR Winingham	Rigging	During safety audit I noticed a frayed strap. Strap wasn't terrible but was starting to show wear.	Strap starting to show wear.	Discarded strap and replaced with new	Continue during pre inspection on everything before use.
9	Mark Musser	Slips/Trips	Very muddy conditions after weekend rains	A slope was the main access to the site and was slippery after the rain	Use excavator to bench steps and remove wet material	
10	Mike Jenkins	Fall Protection	Jumping down from 3' wall onto curing blankets.	Not using proper access and egress.	Discussed with worker importance of using ladders and potential hazards.	Continually teaching new hires of our safety procedures
<b>Bonus</b>	Zackary Rushing	Electric/Tools	Walked over and and seen our subcontractor was cutting boards and using his foot as way to hold the board up while he was cutting. Stop him and asked him if there was a better/safer way for him to perform his job. The sub agreed that it wasn't safe, and he should find a better way even if it took more time.	Trying to take shortcuts and potentially running the risk of injury too himself had the circular saw jumped.	Stopping work, and getting a better safer surface to cut the materials on.	Slowing down, and doing what's right, and safe for everyone.
	Michael Kiwala	JSA / Planning	JSA filled out poorly	Lack of description / planning	Worked with individual to create a good JSA for task performed	Don't rush through JSA process. This is what keeps us safe and have us go home safely